

1001/APSCT /

30 Jan 2024

(Name of firms)

CALL FOR QUOTATION

Sir/Madam,

1. We are intending to refill and replacement of following fire extinguishers for our school:-

Ser No	Nomenclature	Specification	A/U	Qty	Rate
(a)	CO 2- 2 Kg	<ul style="list-style-type: none">- Fire Rating: IS 15683: 34B, Fire Rating EN3: 34B- International Certifying body: BIS, Eurocert.- Squeeze Grip, Controllable Discharge- Used / Unused Indicator, Discharge Horn, Applicable on Class B, C & E- Warranty _____ Years	Nos	12	
(b)	CO 2- 4.5 Kg	<ul style="list-style-type: none">- Fire Rating: IS 15683: 55B, Fire Rating EN3: 55B- International Certifying body: BIS, Eurocert.- Trolley Mounted- Used / Unused Indicator, Discharge Horn, Applicable on Class B, C & E- Warranty _____ Years	Nos	09	
(c)	ABC 2 Kg MAP	<ul style="list-style-type: none">- Fire Rating IS15683:3A, 70B- Fire Rating EN3: 13A, 55B- International Certification standard: EN-3, PED, IS 15683- International Certifying body: LPCB, BIS, Eurocert- Can Construction : Deep Draw & MIG CO2 welding- Valve Construction: Forging & Machining- Magnetic Pressure Gauge- Can Internal Coating : Epoxy Powder- Can External Coating : Epoxy Powder- Helium Leak Detection Test- HPT Certificate for every cylinder- Warranty _____ years	Nos	20	



Ser No	Nomenclature	Specification	A/U	Qty	Rate
(d)	ABC 4 Kg MAP	<ul style="list-style-type: none"> - Fire Rating IS15683:4A, 144B - Fire Rating EN3: 21A, 144B - International Certification standard: - EN-3, PED, IS 15683 - International Certifying body: - LPCB, BIS, Eurocert - Can Construction : Deep Draw & MIG CO2 welding - Valve Construction: Forging & Machining - Magnetic Pressure Gauge, ELPDM Hose Pipe - Can Internal Coating : Epoxy Powder - Can External Coating : Epoxy Powder - Helium Leak Detection Test - HPT Certificate for every cylinder - Warranty _____ years 	Nos	39	

2. You are requested to put your rates including GST of per items so as to reach this office by 10 Feb 2024 in a sealed envelope. Quotation received thereafter will not be accepted. No intimation will be given regarding acceptance and rejections.

3. Firm/ vendor for supply of stores will be decided by the School Purchase Committee/Board of Officers based on lowest rates and quality of stores being provided by them.

4. Guarantee and warranty of the stores for stipulated time frame will also be strictly adhered to.

5. The following services/ certificate are also required to be provided by the firms:-

(a) HPT (Hydrostatic Pressure Test) certificate of every fire extinguisher from reputed Company.

(b). Performance certificate of Every Fire Extinguisher.

(c) Yearly visit to school premises to check the product performance & submit survey report of extinguisher to the concern Authority.

(d). Refilling / replacement of fire extinguisher will be done in School premises only.

6. Only appropriate charges of GST and service charges, if any will be accepted.

7. Stores so demanded be provided/supply by Firm/vendor in School office and no extra charges on account of transportation will be added later on.



Yours sincerely

Bhargava
(Mrs Bhavna Bhargava)
Offg Principal

Pic